

Promat

PROMASEAL® Wall Collar Plastic Pipe Penetration Seals



www.promat.com.au



PROMASEAL® Wall Collar is designed for insertion into wall elements made of calcium silicate, plasterboard, Speedpanel, concrete, AAC panels or masonry. The collar has been tested up to -/120/120 fire resistance with HDPE or uPVC pipes up to 162mm outside diameter through these wall elements (with an equal or greater fire resistance level) in accordance with the criteria of AS1530: Part 4: 2014, AS4072: Part 1: 2005 and BS 476: Part 20: 1987 The collar can be split for retrofit where necessary.

Minimum thicknesses of the partition/wall using single collar on plastic pipes up to 110mm and 162mm outside diameter are 48mm and 116mm respectively.

If the partition/wall is thinner than 120mm, PROMASEAL®-A Acrylic Sealant may need to be applied to the section of collar that extends from the partition/wall in order to maintain insulation.

PROMASEAL® Wall Collar can be positioned at an angle providing the exposure is similar to the original test. Please consult Promat for details of the application requirements.

Plastic pipe penetration seals

Retrofit installation to lightweight partitions (or plasterboard walls)

Locate the collar in a central position on the partition/wall. All annular gaps between the collar and the partition/wall must be no greater than 20mm and filled with PROMASEAL®-A Acrylic Sealant to a minimum depth of 32mm. If the gap is greater than 20mm, reduce it with the same materials used to build the wall/partition or backfill with PROMASEAL® Mortar.

If there is a possibility of pipe movement that might cause cracks in the mortar sealing between the plastic pipe and the floor, it is advisable to seal the pipe with PROMASEAL®-A Acrylic Sealant to prevent cold smoke ingress. However, this is not necessary for the required fire resistance performance.

Do not obstruct the perforated mesh at the ends of the collar when sealing any gaps.

Maximum thickness of the partition/wall is 146mm. For greater thickness, two collars are recommended to ensure outer face of the collar is embedded no more than 14mm measured from the partition/wall surface. It is permissible for the collar body to extend beyond surface of the wall.

Dimension




Code no.		FCW 40	FCW 50	FCW 65	FCW 100	FCW 150
Pipe nominal diameter	mm	40	50	65	100	150
Body	H mm	120	120	120	120	120
	D1 mm	80*	90*	107*	153*	203*
	D2 mm	47	60	75	116	164


* Additional allowance of 3mm for clip.

Up to -/120/120 fire resistance in accordance with the requirements of BS 476: Part 20: 1987, AS 1530: Part 4: 2014 and AS 4072: Part 1: 2005; insulation criteria will vary depending on type and size of plastic pipes AND the type of separating elements

- ① PROMASEAL® Wall Collar
- ② Various plastic piping, e.g. HDPE, uPVC



- ④ All gaps caulked with PROMASEAL®-A Acrylic Sealant to achieve the required fire resistance performance
- ⑤ Fire resistant concrete/masonry walls
- ⑥ Fire resistant steel/timber framed lightweight partitions
- ⑦ Hebel and three layers of 16mm thick plasterboard wall



Promat provides a wide range of systems for compartmentation, fire resistant air and cable ducts, structural steel protection, fire stopping and partitions. For assistance with any passive fire protection problems, contact the nearest Promat office.

Promat Australia Pty Ltd

South Australia office

1 Scotland Road
Mile End South, SA 5031
T 1800 PROMAT (776 628)
F +61 (8) 8352 1014

New South Wales office

Unit 1, 175 Briens Road
Northmead, NSW 2152
T 1800 PROMAT (776 628)
F +61 (2) 9630 0258

Victoria office

Suite 205, 198 Harbour Esplanade
Docklands, VIC 3008
T 1800 PROMAT (776 628)
F 1800 334 598

Queensland office

433 Logan Road
Stones Corner, QLD 4120
T 1800 011 376
F 1800 334 598

E mail@promat.com.au

www.promat.com.au

- The technical data provided in this publication is based on mean values prevalent at time of publication and is thus subject to fluctuation. It should not be regarded as a guarantee to system performance.
- All data contained herein conforms to and frequently surpasses generally accepted fire protection standards recognised by most professional fire science practitioners and regulatory authorities worldwide. The same general principle is equally applicable to all Promat products and systems. Promat has access to a considerable body of test authentication data and this can be provided on a complimentary basis upon request. It should be noted however that this publication replaces all previous editions in its entirety. Any form of reproduction by any means – manual, electronic, digital or otherwise – is strictly prohibited and subject to prior approval in writing from Promat. All rights related or connected to the Promat logo, Promat registered trademarks, featured illustrations, written information and technical reports in this publication are the sole, exclusive and copyright property of Promat and its legal partner companies.

Etex is a Belgian industrial group that specialises and markets high quality building materials and systems. Founded since 1905 and headquartered in Brussels, Belgium, Etex currently operates in 107 factories and 102 subsidiaries across 42 countries, employs more than 15,000 people and is one of the largest fibre cement producers in the world.

Through its subsidiaries, the group offers an extensive range of products: small and large roofing materials, cladding and building boards, passive fire protection systems.

Etex aims to be a professional, solid partner for all kinds of building projects.

